

Drinking Water Quality and Compliance 2017 Annual Notice to Consumers

The Water Security Agency requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Valley Ridge Community Co-op's** water quality and sample submission compliance record for the 2017 calendar year. This report was completed on February 26, 2018. Readers should refer to the Water Security Agency's "Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202" for more information on minimum sample submission requirements. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on water regulations and the nature and significance of specific water tests, more detailed information is available from: www.saskh2o.ca.

Water Quality Standards

Bacteriological Quality

<u>Parameter/Location</u>	<u>Limit</u>	<u># of Regular Samples Required to be Submitted</u>	<u># of Regular Samples Submitted (%)</u>	<u>Total # of Samples Submitted (Reg+Rpt+Spcl)</u>	<u>Total # of Positive Samples Submitted (%)</u>
Total Coliform and Background Bacteria	0 Organisms/100 mg/L Less than 200 Orgs./100 mL	24	24 (100%)	24	0 (0%)

The owner/operator is responsible to ensure that one hundred percent of all bacteriological samples are submitted as required. All waterworks are required to submit samples for bacteriological water quality, the frequency of monitoring depends on the population served by the waterworks.

Water Disinfection – Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

<u>Parameter</u>	<u>Minimum Limit (mg/L)</u>	<u>Free Chlorine Residual Range</u>	<u>Total Chlorine Residual Range</u>	<u>Average Free Chlorine (mg/L)</u>	<u>Average Total Chlorine (mg/L)</u>
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.00 – 1.21 mg/l	0.2 – 1.2 mg/l	0.81 mg/l	1.2 mg/l

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual OR 0.5 mg/L total chlorine residual is required at all times throughout the distribution system unless otherwise approved.

Chemical – Trihalomethanes

Parameter	Limit IMAC (ug/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	100	101.3	4	4

Trihalomethanes are generated during the water disinfection process as a by-product of reactions between chlorine and organic material. Trihalomethanes are generally found only in drinking water obtained from surface water supplies. Trihalomethanes are to be monitored on a quarterly basis and the Interim Maximum Acceptable Concentration (IMAC) result is expressed as an average of 4 quarterly samples. Only water supplies derived from surface water or groundwater under the influence of surface water are usually required to monitor for trihalomethanes.

Water Disinfection – Free and Total Chlorine Residual for Water In the Distribution System from Daily Test Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements of Free OR Total Chlorine Residuals
Free Chlorine Residual	at least 0.10	.2- 1.46 mg/l	348	0
Or Total Chlorine Residual	at least 0.50	.44 – 3.6 mg/l	348	1

A minimum of 0.10 milligrams per litre (mg/L) free chlorine residual or a minimum of 0.50 mg/l total chlorine residual is required for water throughout the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free and total chlorine residual tests performed, the overall range of free and total chlorine residuals (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirements.

More information on water quality and sample submission performance may be obtained from www.saskh2o.ca or from:

***Valley Ridge Community Co-op
Box
MOOSE JAW SK
S6K 1C1***